



U.S. Micro-Solutions, Inc. * 302 Unity Plaza * Latrobe, PA 15650
 Phone: (724) 853-4047 Fax: (724) 853-4049 AIHA-LAP, LLC EMLAP #103009
www.usmslab.com

Customer Name:	Northern Air Flow	Sample Date:	August 22, 2022
Customer Address:	PO Box 085595	Date Received:	August 23, 2022
	Racine, WI 53406	Date of Report:	August 30, 2022
Customer Phone:	(262) 639-6796	Fax:	
PO Number:	082222	Attention:	T Mikulecky
Project Name/Number:	The Compounder		

Customer sample numbers below are uniquely identified by prefixing Laboratory # 88697-22

Bioaerosol Sample(s) for Bacterial Analysis - Analytical Method MIC 05

Sample Number	Sample Description	Results of Microbial Analysis	Raw CTs
1	ISO Class 5 Viable Air Level: Count Below Action Level	No of Personnel in Room: 1	
	LAFW 214668070822	Total Microbial Count < 1 CFU/m ³ of air	
No growth			
Total Raw Count: <1		Pore Correction Factor 0	
Total Volume: 1000 liters of air			
Analytical Sensitivity: 1 CFU/m ³ of air			
3	ISO Class 5 Viable Air Level: Count Below Action Level	No of Personnel in Room: 1	
	LAFW 214667070822	Total Microbial Count < 1 CFU/m ³ of air	
No growth			
Total Raw Count: <1		Pore Correction Factor 0	
Total Volume: 1000 liters of air			
Analytical Sensitivity: 1 CFU/m ³ of air			
5	ISO Class 7 Viable Air Level: Count Below Action Level	No of Personnel in Room: 1	
	IV Room	Total Microbial Count < 1 CFU/m ³ of air	
No growth			
Total Raw Count: <1		Pore Correction Factor 0	
Total Volume: 1000 liters of air			
Analytical Sensitivity: 1 CFU/m ³ of air			

Air Sampler:	Impaction Head (# of holes)	Media: CT3P	Manufacturer: bioMerieux
SAS	219	Lot Number:	Exp Date:
		1009314980	10/12/22

Notation for Bolded Microbes

USP<797> *Pharmaceutical Compounding-Sterile Preparations* states recovery of any mold, yeast, coagulase-positive *Staphylococcus*, or gram-negative rod requires immediate remediation and investigation into the cause.

Samples are in good condition unless otherwise noted. Results relate only to the samples tested as received. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.

*Fungus (mold, yeast)

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Deanna L. Kiska

Deanna L. Kiska, Ph.D.



U.S. Micro-Solutions, Inc. * 302 Unity Plaza * Latrobe, PA 15650
 Phone: (724) 853-4047 Fax: (724) 853-4049 AIHA-LAP, LLC EMLAP #103009
www.usmslab.com

Customer Name:	Northern Air Flow	Sample Date:	August 22, 2022
Customer Address:	PO Box 085595 Racine, WI 53406	Date Received:	August 23, 2022
Customer Phone:	(262) 639-6796	Date of Report:	August 30, 2022
PO Number:	082222	Fax:	
Project Name/Number:	The Compounder	Attention:	T Mikulecky

Customer sample numbers below are uniquely identified by prefixing Laboratory # 88697-22

Bioaerosol Sample(s) for Bacterial Analysis - Analytical Method MIC 05

Sample Number	Sample Description	Results of Microbial Analysis	Raw CTs
7	ISO Class 8 Viable Air Level: Count Below Action Level Ante Area	Total Microbial Count < 1 No of Personnel in Room: 1 CFU/m ³ of air	1
No growth			
Total Raw Count: <1			
Total Volume: 1000 liters of air			
Analytical Sensitivity: 1 CFU/m ³ of air		Pore Correction Factor	0

Air Sampler:	Impaction Head (# of holes)	Media: CT3P	Manufacturer: bioMerieux
SAS	219	Lot Number:	Exp Date:
		1009314980	10/12/22

Notation for Bolded Microbes

USP<797> *Pharmaceutical Compounding-Sterile Preparations* states recovery of any mold, yeast, coagulase-positive *Staphylococcus*, or gram-negative rod requires immediate remediation and investigation into the cause.

Samples are in good condition unless otherwise noted. Results relate only to the samples tested as received. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.

*Fungus (mold, yeast)

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Deanna L. Kiska

Deanna L. Kiska, Ph.D.



U.S. Micro-Solutions, Inc. * 302 Unity Plaza * Latrobe, PA 15650
 Phone: (724) 853-4047 Fax: (724) 853-4049 AIHA-LAP, LLC EMLAP #103009
www.usmslab.com

Customer Name: Northern Air Flow Sample Date: August 22, 2022
 Customer Address: PO Box 085595 Date Received: August 23, 2022
 Racine, WI 53406 Date of Report: August 30, 2022
 Customer Phone: (262) 639-6796 Fax:
 PO Number: 082222 Attention: T Mikulecky
 Project Name/Number: The Compounder

Customer sample numbers below are uniquely identified by prefixing Laboratory # 88697-22

Bioaerosol Sample(s) for Fungal Analysis - Analytical Method MIC 05

Sample Number	Sample Description	Results of Microbial Analysis	Raw CTs
1F	ISO Class 5 Viable Air Level: Count Below Action Level	No of Personnel in Room: 1	1
	LAFW 214668070822	Total Microbial Count < 1 CFU/m ³ of air	
No growth			
Total Raw Count: <1		Pore Correction Factor	
Total Volume: 1000 liters of air		0	
Analytical Sensitivity: 1 CFU/m ³ of air			
3F	ISO Class 5 Viable Air Level: Count Below Action Level	No of Personnel in Room: 1	1
	LAFW 214667070822	Total Microbial Count < 1 CFU/m ³ of air	
No growth			
Total Raw Count: <1		Pore Correction Factor	
Total Volume: 1000 liters of air		0	
Analytical Sensitivity: 1 CFU/m ³ of air			
5F	ISO Class 7 Viable Air Level: Count Below Action Level	No of Personnel in Room: 1	1
	IV Room	Total Microbial Count < 1 CFU/m ³ of air	
No growth			
Total Raw Count: <1		Pore Correction Factor	
Total Volume: 1000 liters of air		0	
Analytical Sensitivity: 1 CFU/m ³ of air			

Air Sampler:	Impaction Head (# of holes)	Media: SDA w/Lec & Tween	Manufacturer: Hardy
SAS	219	Lot Number:	Exp Date:
		145522	12/11/22

Notation for Bolded Microbes

USP<797> Pharmaceutical Compounding-Sterile Preparations states recovery of any mold, yeast, coagulase-positive *Staphylococcus*, or gram-negative rod requires immediate remediation and investigation into the cause.

Samples are in good condition unless otherwise noted. Results relate only to the samples tested as received. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.

*Fungus (mold, yeast)

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Deanna L. Kiska

Deanna L. Kiska, Ph.D.



U.S. Micro-Solutions, Inc. * 302 Unity Plaza * Latrobe, PA 15650
 Phone: (724) 853-4047 Fax: (724) 853-4049 AIHA-LAP, LLC EMLAP #103009
www.usmslab.com

Customer Name: Northern Air Flow Sample Date: August 22, 2022
 Customer Address: PO Box 085595 Date Received: August 23, 2022
 Racine, WI 53406 Date of Report: August 30, 2022
 Customer Phone: (262) 639-6796 Fax:
 PO Number: 082222 Attention: T Mikulecky
 Project Name/Number: The Compounder

Customer sample numbers below are uniquely identified by prefixing Laboratory # 88697-22

Bioaerosol Sample(s) for Fungal Analysis - Analytical Method MIC 05

Sample Number	Sample Description	Results of Microbial Analysis	Raw CTs
7F	ISO Class 8 Viable Air Level: Count Below Action Level Ante Area	Total Microbial Count < 1 No growth	No of Personnel in Room: 1 CFU/m ³ of air
Total Raw Count: <1 Total Volume: 1000 liters of air Analytical Sensitivity: 1 CFU/m ³ of air		Pore Correction Factor	0

Air Sampler:	Impaction Head (# of holes)	Media: SDA w/Lec & Tween Lot Number:	Manufacturer: Hardy Exp Date:
SAS	219	145522	12/11/22

Notation for Bolded Microbes

USP<797> *Pharmaceutical Compounding-Sterile Preparations* states recovery of any mold, yeast, coagulase-positive *Staphylococcus*, or gram-negative rod requires immediate remediation and investigation into the cause.

Samples are in good condition unless otherwise noted. Results relate only to the samples tested as received. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.

*Fungus (mold, yeast)

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Deanna L. Kiska

Deanna L. Kiska, Ph.D.



U.S. Micro-Solutions, Inc. * 302 Unity Plaza * Latrobe, PA 15650
 Phone: (724) 853-4047 Fax: (724) 853-4049 AIHA-LAP, LLC EMLAP #103009
www.usmslab.com

Customer Name: Northern Air Flow Sample Date: August 22, 2022
 Customer Address: PO Box 085595 Date Received: August 23, 2022
 Racine, WI 53406 Date of Report: August 30, 2022
 Customer Phone: (262) 639-6796 Fax:
 PO Number: 082222 Attention: T Mikulecky
 Project Name/Number: The Compounder

Customer sample numbers below are uniquely identified by prefixing Laboratory # 88697-22

Contact Plate(s) for Bacterial Analysis - Analytical Method MIC 05

Sample Number	Sample Description	Results of Microbial Analysis	Raw CTs
2	ISO Class 5 Viable Surface Level: Count Below Action Level LAFW 214668070822	Total Microbial Count < 1 No growth	No of Personnel in Room: 1 CFU/plate
Total Raw Count: <1 Analytical Sensitivity: 1 CFU/plate			
4	ISO Class 5 Viable Surface Level: Count Below Action Level LAFW 214667070822	Total Microbial Count < 1 No growth	No of Personnel in Room: 1 CFU/plate
Total Raw Count: <1 Analytical Sensitivity: 1 CFU/plate			
6	ISO Class 7 Viable Surface Level: Count Below Action Level IV Room	Total Microbial Count < 1 No growth	No of Personnel in Room: 1 CFU/plate
Total Raw Count: <1 Analytical Sensitivity: 1 CFU/plate			

Notes:	Media: CT3P	Manufacturer: bioMerieux
	Lot Number:	Exp Date:
	1009314980	10/12/22

Notation for Bolded Microbes

USP<797> Pharmaceutical Compounding-Sterile Preparations states recovery of any mold, yeast, coagulase-positive *Staphylococcus*, or gram-negative rod requires immediate remediation and investigation into the cause.

Samples are in good condition unless otherwise noted. Results relate only to the samples tested as received. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.
 *Fungus (mold, yeast)

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Deanna L. Kiska

Deanna L. Kiska, Ph.D.



U.S. Micro-Solutions, Inc. * 302 Unity Plaza * Latrobe, PA 15650
 Phone: (724) 853-4047 Fax: (724) 853-4049 AIHA-LAP, LLC EMLAP #103009
www.usmslab.com

Customer Name:	Northern Air Flow	Sample Date:	August 22, 2022
Customer Address:	PO Box 085595 Racine, WI 53406	Date Received:	August 23, 2022
Customer Phone:	(262) 639-6796	Date of Report:	August 30, 2022
PO Number:	082222	Fax:	
Project Name/Number:	The Compounder	Attention:	T Mikulecky

Customer sample numbers below are uniquely identified by prefixing Laboratory # 88697-22

Contact Plate(s) for Bacterial Analysis - Analytical Method MIC 05

Sample Number	Sample Description	Results of Microbial Analysis	Raw CTs
8	ISO Class 8 Viable Surface Level: Count Below Action Level Ante Area	Total Microbial Count < 1 No growth	No of Personnel in Room: 1 CFU/plate
Total Raw Count: <1 Analytical Sensitivity: 1 CFU/plate			

Notes:	Media: CT3P	Manufacturer: bioMerieux
	Lot Number:	Exp Date:
	1009314980	10/12/22

Notation for Bolded Microbes

USP<797> *Pharmaceutical Compounding-Sterile Preparations* states recovery of any mold, yeast, coagulase-positive *Staphylococcus*, or gram-negative rod requires immediate remediation and investigation into the cause.

Samples are in good condition unless otherwise noted. Results relate only to the samples tested as received. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.
 *Fungus (mold, yeast)

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Deanna L. Kiska

Deanna L. Kiska, Ph.D.



Customer Name: Northern Air Flow Sample Date: August 22, 2022
 Customer Address: PO Box 085595 Date Received: August 23, 2022
 Racine, WI 53406 Date of Report: August 30, 2022
 Customer Phone: (262) 639-6796 Fax:
 PO Number: 082222 Attention: T Mikulecky
 Project Name/Number: The Compounder

Customer sample numbers below are uniquely identified by prefixing Laboratory # 88697-22

Contact Plate(s) for Fungal Analysis - Analytical Method MIC 05

Sample Number	Sample Description	Results of Microbial Analysis	Raw CTs
2F	ISO Class 5 Viable Surface Level: Count Below Action Level	No of Personnel in Room: 1	1
	LAFW 214668070822	Total Microbial Count < 1 CFU/plate	
No growth			
Total Raw Count: <1			
Analytical Sensitivity: 1 CFU/plate			
4F	ISO Class 5 Viable Surface Level: Count Below Action Level	No of Personnel in Room: 1	1
	LAFW 214667070822	Total Microbial Count < 1 CFU/plate	
No growth			
Total Raw Count: <1			
Analytical Sensitivity: 1 CFU/plate			
6F	ISO Class 7 Viable Surface Level: Count Below Action Level	No of Personnel in Room: 1	1
	IV Room	Total Microbial Count < 1 CFU/plate	
No growth			
Total Raw Count: <1			
Analytical Sensitivity: 1 CFU/plate			

Notes:	Media: SDA w/Lec & Tween	Manufacturer: Hardy
	Lot Number:	Exp Date:
	145522	12/11/22

Notation for Bolded Microbes

USP<797> *Pharmaceutical Compounding-Sterile Preparations* states recovery of any mold, yeast, coagulase-positive *Staphylococcus*, or gram-negative rod requires immediated remediation and investigation into the cause.

Samples are in good condition unless otherwise noted. Results relate only to the samples tested as received. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.

*Fungus (mold, yeast)

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Deanna L. Kiska

Deanna L. Kiska, Ph.D.



U.S. Micro-Solutions, Inc. * 302 Unity Plaza * Latrobe, PA 15650
 Phone: (724) 853-4047 Fax: (724) 853-4049 AIHA-LAP, LLC EMLAP #103009
www.usmslab.com

Customer Name: Northern Air Flow
 Customer Address: PO Box 085595
 Racine, WI 53406
 Sample Date: August 22, 2022
 Date Received: August 23, 2022
 Date of Report: August 30, 2022
 Customer Phone: (262) 639-6796
 PO Number: 082222
 Project Name/Number: The Compounder
 Fax: Attention: T Mikulecky

Customer sample numbers below are uniquely identified by prefixing Laboratory # 88697-22

Contact Plate(s) for Fungal Analysis - Analytical Method MIC 05

Sample Number	Sample Description	Results of Microbial Analysis	Raw CTs
8F	ISO Class 8 Viable Surface Level: Count Below Action Level Ante Area	Total Microbial Count < 1 No growth	No of Personnel in Room: 1 CFU/plate
Total Raw Count: <1			
Analytical Sensitivity: 1 CFU/plate			

Notes:	Media: SDA w/Lec & Tween	Manufacturer: Hardy
	Lot Number: 145522	Exp Date: 12/11/22

Notation for Bolded Microbes

USP<797> *Pharmaceutical Compounding-Sterile Preparations* states recovery of any mold, yeast, coagulase-positive *Staphylococcus*, or gram-negative rod requires immediated remediation and investigation into the cause.

Samples are in good condition unless otherwise noted. Results relate only to the samples tested as received. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.

*Fungus (mold, yeast)

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Deanna L. Kiska

Deanna L. Kiska, Ph.D.



U.S. Micro-Solutions, Inc. * 302 Unity Plaza * Latrobe, PA 15650
 Phone: (724) 853-4047 Fax: (724) 853-4049 AIHA-LAP, LLC EMLAP #103009
www.usmslab.com

Customer Name:	Northern Air Flow	Sample Date:	August 22, 2022
Customer Address:	PO Box 085595	Date Received:	August 23, 2022
	Racine, WI 53406	Date of Report:	August 30, 2022
Customer Phone:	(262) 639-6796	Fax:	
PO Number:	082222	Attention:	T Mikulecky
Project Name/Number:	The Compounder		

Customer sample numbers below are uniquely identified by prefixing Laboratory # 88697-22

Media Control(s) Analysis - Analytical Method MIC 05

Sample Number	Sample Description	Results of Microbial Analysis
9	Positive	Growth of Bacillus subtilis Growth of Pseudomonas aeruginosa Growth of Staphylococcus aureus
10	Negative	No growth*
*Results are not blank corrected		

	Media: CT3P	Manufacturer: bioMerieux
	Lot Number:	Exp Date:
	1009314980	10/12/22

Notation for Bolded Microbes

USP<797> *Pharmaceutical Compounding-Sterile Preparations* states recovery of any mold, yeast, coagulase-positive *Staphylococcus*, or gram-negative rod requires immediate remediation and investigation into the cause.

Samples are in good condition unless otherwise noted. Results relate only to the samples tested as received. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Deanna L. Kiska

Deanna L. Kiska, Ph.D.



U.S. Micro-Solutions, Inc. * 302 Unity Plaza * Latrobe, PA 15650
 Phone: (724) 853-4047 Fax: (724) 853-4049 AIHA-LAP, LLC EMLAP #103009
www.usmslab.com

Customer Name:	Northern Air Flow	Sample Date:	August 22, 2022
Customer Address:	PO Box 085595	Date Received:	August 23, 2022
	Racine, WI 53406	Date of Report:	August 30, 2022
Customer Phone:	(262) 639-6796	Fax:	
PO Number:	082222	Attention:	T Mikulecky
Project Name/Number:	The Compounder		

Customer sample numbers below are uniquely identified by prefixing Laboratory # 88697-22

Media Control(s) Analysis - Analytical Method MIC 05

Sample Number	Sample Description	Results of Microbial Analysis
9F	Positive	Growth of Candida albicans Growth of Aspergillus brasiliensis
10F	Negative	No growth*
*Results are not blank corrected		

		Media: SDA w/Lec & Tween	Manufacturer: Hardy
		Lot Number:	Exp Date:
		145522	12/11/22

Notation for Bolded Microbes

USP<797> *Pharmaceutical Compounding-Sterile Preparations* states recovery of any mold, yeast, coagulase-positive *Staphylococcus*, or gram-negative rod requires immediate remediation and investigation into the cause.

Samples are in good condition unless otherwise noted. Results relate only to the samples tested as received. Results are reported as calculated. For biological data, the first and/or second digit should be considered significant.

When providing duplicates of this report, the document should be provided in total and not in section in accordance with AIHA-LAP, LLC. Any unauthorized or improper disclosure, copying, distribution, use, or falsification of these results is prohibited. USMS shall have no liability to the Customer or the Customer's customer for opinions stated, recommendations made, actions taken, or conduct implemented based on the test results reported.

Technical Manager:

Deanna L. Kiska

Deanna L. Kiska, Ph.D.



U.S. MICRO-SOLUTIONS INC.
AN ENVIRONMENTAL MICROBIOLOGY LAB

RECOMMENDED ACTION LEVELS FOR MICROBIAL CONTAMINATION

USP 797 states that the tables of recommended action levels are intended to be used as guidelines only, and "Action levels are determined on the basis of CFU data gathered at each sampling location and trended over time." "Highly pathogenic microorganisms (e.g., Gram-negative rods, coagulase-positive *Staphylococcus*, molds, and yeasts)...must be immediately remedied, regardless of CFU count."

(Version USP 40-NF 35)

Action Level for BIOAEROSOL Samples	
CLASSIFICATION	Total CFU per m ³
ISO Class 5	>1
ISO Class 6	>10
ISO Class 7	>10
ISO Class 8 or worse	>100

Action Level for GLOVED FINGERTIP Samples		
Total CFU for both hands		
	Initial Garbing	Subsequent (Post Media Fill)
	>0	>3

Action Level for SURFACE Samples	
CLASSIFICATION	Total CFU per plate, swab, or area sampled
ISO Class 5	>3
ISO Class 6	>5
ISO Class 7	>5
ISO Class 8 or worse	>100

USP <797> Standard Operating Procedure

- **Incubation**
 - Samples are placed in the incubator on the day that they are received in the laboratory.
 - Bacterial agar plates: 30-35°C for 48-72 hours.
 - Fungal agar plates: 20-25°C for 5-7 days.
 - Single plate method agar plates: 30-35°C for 48-72 hours and then 20-25°C for 5-7 additional days.
 - Media fill vials: 20-25°C for 7 days and then 30-35°C for 7 days.
 - Incubator temperatures are monitored 24/7 via a wireless temperature monitoring and alert system.
- **Identification** - species identification performed by MALDI-TOF mass spectrometry.
- **Positive Controls** - performed with the following organisms when requested:
 - *Staphylococcus aureus* ATCC 6538
 - *Pseudomonas aeruginosa* ATCC 9027
 - *Bacillus subtilis* ATCC 6633
 - *Candida albicans* ATCC 10231
 - *Aspergillus brasiliensis* ATCC 16404
- **Accreditation**
 - ISO/IEC 17025:2017 accreditation for bacterial and fungal analysis through the American Industrial Hygiene Association (AIHA-LAP, LLC #103009).

302 Unity Plaza ▲ Latrobe, PA 15650 ▲ P: 724.853.4047 ▲ F: 724-853-4049 ▲ info@usmslab.com

QLT 02 F1 v2 DCR 22-071 Effective 03-08-22